

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES  
L.M. Dey Garden, D.H. Road, Silpara, Pin - 700008**

Memo No : IND/WB/FES/20182019/49421

DATE: 02/04/2019

**From :**

**The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.**

**To :**

**AALOKE BHARTI MODEL SCHOOL  
RANA PARK, AATGHARA, P.O. DALUA, P.S. SONARPUR, SOUTH 24 PARGANAS,  
KOLKATA - 700152  
Baruipur F.S., sonarpur,  
South 24 Parganas - 700152 .**

**Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under Group Educational at the premises no.- RANA PARK, AATGHARA, P.O. DALUA, P.S. SONARPUR, Dist.- SOUTH 24 PARGANAS, KOLKATA - 700152.**

This is in reference to your Application No. IND/WB/FES/20182019/49421, dated 02/04/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under Group Educational at the premises no.- RANA PARK, AATGHARA, P.O. DALUA, P.S. SONARPUR, Dist.- SOUTH 24 PARGANAS, KOLKATA - 700152..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Revised Recommendation shall be obtained for vertical Construction of 2nd floor within

next Renewal Date 2) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway. 3) The interior finish decoration of the building shall be made with low flame spread material conforming to the I.S. Specification. 4) To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained. 5) Existing Electrical wiring of the hole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts. 6) A Fire Control Room including a CCTV system will have to be maintained, which observe all floors of the building. 7) The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building. 8) The Employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire & Testing. 9) Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building. 10) Transformer and switch gear room shall be protected with automatic co2 or D.C.P. Fire Extinguishers confirming I.S. specification. 11) A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building. 12) First-Aid Fire Fighting system shall be provided as per I.S. specification. 13) Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times. 14) If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth. 15) Periodical flashing of water from the Hydrant pipe lines shall be made to maintain the efficient working performance of above mentioned system. 16) The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register. 17) Provision of Fire Pump shall have to be made to supply water at the designated pressure and discharge into the water based system which shall be installed. One such other pump shall always be kept on standby basis preferably be of diesel driven type. One such other fire pump shall also be installed independently for sprinkler system. 18) The N.O.C. is valid for 3 (three) year and have to be renewed every year from the date of issue of this letter. 19) Each threeyear a certificate is to be obtained from the Divisional Fire Officer, South 24 Parganas Division, West Bengal Fire & Emergency Services, performance of all the life and fire safety arrangements and installation of the building.

**Divisional Fire Officer**

**West Bengal Fire & Emergency Services**

Signature valid

Digitally signed by DIPAK  
KUMAR GHOSH  
Date: 2019.04.02 17:24:27 IST