

**Government of West Bengal**

Public Health Division Rajpur Sonarpur Municipality

Water Quality Testing Report

Received Sample on date : 10/12/2023


District- South 24 Parganas				Testing date - 10/12/2023												
SL. No.	Block	Location of Source	Type of Source	Sample Collected by : School Staff												
				Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	Sonarpur	Aaloke Bharti Model School, Rana Park, Aatghara	Boring water	-	1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-


Memo No. - 1374

Dated - 11/12/2023

Copy to Principal Aaloke Bharti Model School, Rana Park, Aatghara, Dalua, Sonarpur, West Bengal to inform regarding reference to his letter no.- ABM/PHED/12/2023, Dated- 10/12/2023

  
S. Banerjee  
Lab Assistant

  
Chemist

  
Assistant Engineer  
P.H. Division  
Rajpur Sonarpur Municipality  
PH Division  
Rajpur-Sonarpur Municipality  
West Bengal