Sl.No..... 23/205

Ramakrishna Mission Lokasiksha Parishad
Ramakrishna Mission Ashrama
Narendrapur, Kolkata – 700 103

Water Quality Testing under NRDWQMS Programme in collaboration with PHED, Govt. Of West Bengal

TEST RESULT OF WATER SAMPLE

N.B.: Water samples collected and data supplied by a representative of the school.

	Date: 04.03.26
Name of Owner	: Aaloke Bharti Model School
Location of Water-Source	: At Ground Floor
Address	: "Rana Park", Aatghara, P.O.- Dhalua, P.S.- Narendrapur, Kolkata-700152

Date of Sample Collection	:	..... 02.03.26

Parameters Test Report:

Name of Parameters	Date of Testing	Test Result	Permissible Limit (As per BIS)
pH	02.03.26 04.03.26	**5.51**	(6.5 – 8.5)
Turbidity		0.53 NTU	5 NTU
Hardness		8 mg/L	600 mg/L
Iron		0.01 mg/L	1.0 mg/L
Total Dissolved Solid (TDS)		31 mg/L	2000 mg/L

Bacteriological test Report:

Total coliforms CFU/100ml	Thermo tolerant coliforms CFU/100ml	Date of Testing	Test Result
0	0	02.03.26	contamination not found

Note: Turbidity, Hardness, TDS and Iron values of the water sample are within the permissible limit of BIS. **pH value is below permissible limit.** Bacteriological contamination not found.

Ripan Biswas
04/03/26
.....
Signature of Chemist
Chemist
W. T. Lab
R.K.M.L.S.P., Narendrapur
Kolkata-700103

A. D. Chowdhury
04/3/26
.....
Signature of Bacteriologist
Bacteriologist
W. T. Lab
R.K.M.L.S.P., Narendrapur
Kolkata-700103